

Optimal Decision of Location and Size of Generation System for Minimization of Losses in Standard Bus System

Authors: Shivam Sharma¹; Imran Khan²

¹ AZAD IET, Lucknow; shivam.sharma.881@gmail.com

² AZAD IET, Lucknow, pe.imran@gmail.com

Abstract

Abstract: A competent methodology based on the active power loss reduction for optimal placement and sizing of distributed generators (DGs) in an active distribution network (ADN) with several soft open points (SOPs) is proposed. A series of SOP combinations are explored to generate different network structures and they are utilized in the optimization framework to identify the possible solutions with minimum power loss under normal network conditions. Furthermore, a generalized methodology to optimize the size and the location of a predefined number of DGs with a predefined number of SOPs is presented. A case study on the modified IEEE 33 bus system with three DGs and five SOPs was conducted and hence the overall network power loss and the voltage improvement were examined. The findings reveal that the system loss of the passive network without SOPs and DGs is reduced by 79.5% using three DGs and five SOPs. In addition, this research work introduces a framework using the DG size and the impedance to the DG integration node, to propose a region where the DGs can be optimally integrated into an ADN that includes several SOPs.

Keywords: active distribution network; distributed generation; optimal planning; particle swarm optimization; soft open points

1. Introduction:

Dispersed generators have acquired consideration as it utilizes sustainable and non-environmentally friendly power sources. Disseminated generators (DG) can be a) sustainable power sources, for example, Wind turbines, Solar photovoltaic, Biomass fuel sources or b) non-sustainable power sources, for example, Diesel generator, Small turbines. Circulated generators are neither midway positioned nor dispatchable. It is dispersed inside the circulation framework at or close to stack Center. DGs consolidation in conveyance framework brings about expansion in the feeder limit, higher dependability, brings down frameworks misfortunes, improves voltage profile and improves voltage steadiness of the framework and brings down the pinnacle request coming about into expansion in the existence of framework gear and consequently more number of clients can be served. To profit these benefits, one needs to discover the fitting limit and area of DG, in any case higher DG limit results into higher force misfortunes and increment of framework voltage.

1.1 Distributed Generation in Power Systems

The DGs size ought to be with the end goal that it is equivalent to the absolute heap of the framework in addition to add up to framework misfortunes. Invert power stream results because of higher limit of DG from substation to the source hub. In the writing three strategies are received to track down the ideal size of DGs, they are: scientific, heuristic and advancement procedures. Logical technique requires dull determination of current and voltage after arrangement of DG, which requires additional time. Heuristic strategies are straightforward however the outcomes got from heuristic calculations are not destined to be ideal. Advancement methods can give the best arrangement inside brief span of time for a given dissemination organization.

An examination by the Electric Power Research Institute (EPRI) demonstrates that by 2010, 25% of the new age will be disseminated, an investigation by the Natural Gas Foundation reasoned that this figure could be pretty much as high as 30% [1]. The European Renewable Energy Study (TERES), appointed by the European Union (EU) to analyze the plausibility of EU CO₂-decrease objectives and the EU sustainable power targets, discovered that around 60% of the sustainable power potential that can be used until 20 can be sorted as

decentralized force sources [2].The boundaries for dispersed age (DG) utilized in the writing, nonetheless, are not reliable. This paper presents a conversation of the significant parts of DG and gives the necessary boundaries.

The total set up capacity concerning biomass cogeneration is 4013.55MW [3], abroad with respect to who chief adventure is past bagasse (squander out of coarseness plants). It is assessed that, set up ability might be improved by 5000MW stipulation sugar factories embrace current cogeneration innovations.

Table showcases current establishment limits of inexhaustible assets alongside their possibilities [4].

Table1: Renewable resources installation capacity and their potential

Resource	Potential	Present Installation
Wind	45GW	21.13GW
Small Hydro Project (SHP)	15GW	2.5GW
Solar	50MW/KM	2632MW

1.1.2 Distributed Generation in World (Present Scenario)

- Average annual growth rates of renewable energy capacity and bio fuels production, end-20 to end-2015 [5]



Figure 1.1: Average annual growth rates of renewable energy capacity and bio fuels producti

- Estimated Renewable energy share for Global electricity production End 2015




Figure 1.2: Estimated Renewable energy share for Global electricity production End 2015 [5]

- In the World Renewable power capacities, EU-28, BRICS and top seven countries, End-2015




Figure 1.3: In the World Renewable power capacities, EU-28, BRICS and top seven countries, End-2015[5]

1.2 Optimal Location and Size determination of DG Units

During the most recent twenty years, association of Distribution Generation (DG) units on appropriation feeders has essentially advanced. Dissimilar to shunt capacitors, DG units are not restricted to receptive force age as they can manage genuine and responsive force simultaneously. To this end, association of DG units on conveyance feeders generally affects the exhibition of conveyance organization. With legitimate establishment of DG frameworks, huge advantages could be procured as far as lessening force and energy misfortunes, delivering KVA limit, improving voltage profile, genuine and receptive force stream control, improving organization dependability among others.

Numerous works managing ideal estimating and area of DG units on outspread circulation feeders are explored in this part. Crafted by Willis [6] who utilized the consistently circulated load model in talking about the connection among RPF and the estimating and area of DG units gives an appropriate beginning stage. He introduced an idea called "Zero Point Analysis" and applied it on the feeder. The idea centers around a point on

the feeder (in the event that it exists) where force stream is zero because of the DG unit yield. As needs be, he placed the effect of DG units into two classes:

1. The yield of the DG unit is not exactly the all out load interest of the down stream hubs from the reason behind normal coupling (PCC) to the furthest limit of the feeder. For this situation the force stream in the line are as between the substation and the PCC is diminished. A model of consistently dispersed feeder with 2 miles length and 4MW absolute interest is followed. ADG unit of 1MW is associated 1 mile from the substation, as shown in Fig.1.4. The specked line shows the decrease in power stream profile along the feeder.




Figure 1.4 DG unit output exceeds the total demand of downstream nodes.

Willis [6] dissected the effect of the DG unit on the line misfortunes along these lines to the old 2/3 dependable guideline utilized with capacitors situation on consistently dispersed feeders. He proposed a similar guideline for the DG unit by estimating it to 2/3 of the absolute feeder load, at 2/3 the separation from the substation. The technique consolidates practically the entirety of the weaknesses been expressed so far in the past works. Hoff and Shunger [12] fostered a strategy to recreate the line top force and energy misfortune reserve funds dependent on the day by day load and the PVDG unit yield alongside hardly any appropriation framework qualities. To ascertain the line power misfortunes on 3-stage outspread appropriation feeder, the fundamental condition "3.IF2.R" is applied. In the event that and R are the 1-stage immediate current and the obstruction of the line separately. Henceforth, the prompt line power misfortune saving (SL) in a line area influenced by PVDG unit is equivalent to the distinction between misfortunes when associating PVDG unit(s). This connection is determined as Eq. underneath:

$$SL = 3 \cdot I_f^2 \cdot R - 3(I_f - I_{pv})^2 \cdot R = 6 \cdot R \cdot I_f \cdot I_{pv} - 3 \cdot R \cdot I_{pv}^2 \quad (1)$$

The formula of LS is expressed for any n-sections radial feeder shown in Fig.2 as follows:

$$SL = (6 \cdot I_f \cdot I_{pv} \sum_{i=1}^n a_i b_i R_i) - (3 \cdot I_{pv}^2 \sum_{i=1}^n b_i^2 R_i) \quad (2)$$

Where, computer based intelligence is the small amount of current streams in segment I as far as IF while bi is the negligible part of IPV summation on the rest of after I as far as absolute IPV overall feeder.

The methodology includes the load flow analysis and the PSO using MATLAB programming.

2.1 Power Flow Solutions

In elegant, cutting edge qualities vegetation are found a few distances out of customer areas, or that specifications results among a gigantic amount's about strength break at the energy gadget. Establishment of solidness DGs may furthermore lessens the force misfortune circumstance their accommodating spots are settled on. To decide the debuts areas concerning a doublet with respect to DGs, the IEEE benchmarked 31-transport arrangement set up of Fig. is ceaseless as a test structures [1], [2]. The work area among Figure 2.is at present examined because of 2 outstanding cases with honor in impersonation of author or burden [17]. In others phrases, powers go along with the float out of the kth generator after a few stores inside the ahead case, and as much as assumption the ones floats out of various plants in impersonation of the lth load intestinal the subsequent case. These twins requirements are demonstrated between Figures 2.2 and 2.3, individually. The connected boundaries are characterized especially follows:

- 1) Pk: Power given through the use of the kth plants inside a control local area;
- 2) Pl: confine ate up by utilizing way of the lth loads between a breaking point local area;
- 3) Pk,l: energy chain past the kth generators in impersonation of the lth load;

four) $F_{j,l,okay}$: control stream from the k th turbines in impersonation of the l th relegate through transport j related in congruity with the l th masses;

five) $F_{k,j,l}$: energy stream out of the k th issue in impersonation of the l th trouble through transport j associated in congruity with the k th generator.

In blend concerning joining examples characterized earlier, the law of decide 2. do hold communicated through method of the worked on visit displayed into Fig. 4 all in all with the worries over best strength ages and appoint utilizations.

The division in transports I then j of Figure 2.4 may moreover live addressed along with the worked on soloist circuits as a decent arrangement demonstrated among Figure 2.5. Then, at that point, the entire energy loss of the entire gadget can be determined through adding the misfortunes of all branches each time the DG is snared to any transport [1]. In various expressions, the framework in Figure 2.4 be capable be rearranged so a circuit of Figure 2.Five by utilizing that represent considerable authority in the association the different DG then the standard misfortune. In the equivalent way, the whole powers framework (Figure. 2.1) do likewise stand rearranged.




Figure. 2. IEEE benchmarked 31-bus system [6]




Figure 2.2 Power flow from the k th generator to the several loads.[12]




Figure 2.3 Power drift from the several turbines to the l th load.[20]




Figure 2.4 Simplified circuit with most effective strength generations and consumptions. [20]




Figure 2.5 Simplified unit circuit between buses. [20]

2.2 Problem identification

In realistic eventualities, it isn't always viable to install the DGs on each load bus to decrease the losses. In spite of several blessings, setup of DGs to the energy grid requires careful issues for several elements which include:

- Stability
- Reliability
- Protectioncoordination
- Powerloss
- Powerpleasantproblems

Mostofall, before multiple DGs are related to the energygrid, the choice in their most fulfilling places and sizes may be very crucial in order to maximize the useful out comes of the DGs.

In this work, will apply the PSO technique to minimize the losses and reduce the general generation price.

2.3 ParticleSwarmOptimization

Evolutionary computation, gives sensible advantages to there searcher facing tough optimizations problems. These blessings are multifold, such as the simplicity of the technique, its sturdy responses to changing state of affairs, its flexibility, and many exclusive aspects. The evolutionary set of policies may be applied to issues in which heuristic solutions are not to be hadorusually effects in unsatisfactory outcomes. A sast opend result, evolutionary algorithms have recently acquired progressed interest, especially in regards to them anners in which they will be implemented for practical hassle solving. Usually grouped beneath the time periods evolutionary computations or evolutionary algorithms, they locate the domains of genetical algorithms [2], evolution strategies [10],[11], evolutionary programming[1], and genetic programming[7]. They all proportion common place conceptual bases of simulating the evolution of men and women systems through methods of choice, mutation, and duplicate. The approaches depend upon the perceived overall performance of the character structures as defined with the aid of the hassle. Compared to other international optimization strategies, evolutionary algorithms (EA) are easy to enforce and very regularly they offer good enough answers. The float chart of an EA is illustrated in Figure2.6. A population of candidate solutions (for the optimization mission to be solved) is initialized. New solutions are created through applying duplicate operators (mutationand/orcrossover). The health (how authentic the solutions are) of the resulting solutions are evaluated and suitable desire method is then carried out to decide which solutions are to be maintained in to the subsequent technology. The technique is then iterated.

For severa issues a simple Evolutionary set of rules is probably correct enough to discover the popular answer. As stated inside the literature, there are various types of issues where an immediate evolutionary set of rules could fail to gain a convenient (maximum useful) solution [8, 9, 13, 14]. This virtually paves way to the need for hybridization of evolutionary algorithms with other optimization algorithms, device getting to know techniques, heuristics and many others. Some of the feasible motives for hybridization are as follows [12]:

1. To improve the overall performance of the evolutionary algorithm (example:speedofconvergence)
2. To enhance the satisfactory of the answers acquired by way of the evolutionary algorithm

3. To contain the evolutionary set of rules as part of a bigger device

In 1995, Wolpert and Macready [15] showed that each one calculations that quest for an extremum of an expense work perform precisely the indistinguishable, while arrived at the midpoint of over all plausible expense abilities. As indicated by the creators, whenever set of rules A beats calculation B on a couple of cost capacities, then, at that point freely speakme there should exist precisely as numerous different abilities where B outflanks A. Subsequently, from a difficulty addressing point it is hard to figure a recognizable enhancement set of decides that could clear up every one of the issues. Hybridization can be the significant thing to determine reasonable issues. To outline the acknowledgment of mixture strategies, they looked through the assortment of guides showing up in a portion of the acclaimed logical data sets explicitly Science Direct [12], IEEE-Xplore [6], and Springer Link [7] utilizing the key expressions "crossover developmental" and "half and half hereditary" and the inquiry results are classified underneath. Since no separating was utilized inside the inquiry, the quantity of significant papers is likely lower than the figures expressed.




Figure 2.6 Flowchart of an evolutionary algorithm [3]

Figure 2.7 represents a couple of opportunities for hybridization. From instatement of people to the period of off springs, there are masses of freedoms to incorporate various strategies/calculations and so forth Populace might be instated with the guide of consolidating respected arrangements or through utilizing heuristics, nearby inquiry and so forth Nearby pursuit methods might be incorporated inside the underlying people members or a portion of the off springs. Developmental calculations can be hybridized via utilizing administrators from different calculations (or calculations themselves) or by utilizing fusing space specific information. Transformative arrangement of rules lead is resolved by means of the misuse and investigation relationship kept sooner or later of the run. Versatile developmental calculations have been worked for initiating abuse/investigation connections that stay away from the awkward union issue and streamline the last results. The exhibitions of the transformative calculation can be ventured forward by utilizing consolidating issue specific expertise for specific issues.




Figure 2.7 Hybridization perspective in an evolutionary algorithm

Particle Swarm Optimization (PSO) is an evolutionary computation technique, which is inspired by flocks of birds and shoals of fish. In PSO, a number of simple entities (the particles) are placed in the space of some problem and each evaluates its fitness as its current location. Each particle determines its movement through the space by considering the particle which had the best fitness and the history of its own, then it moves with a velocity. At last, the swarm is liable to move near the best area. The speed and position of every molecule is balanced by the accompanying formulas:

$$V_{id} = W \cdot V_{id} + c_1 \cdot \text{Rand}() \cdot (P_{id} - X_{id}) + c_2 \cdot \text{Rand}() \cdot (P_{gd} - X_{id})$$

$$X_{id} = X_{id} + V_{id}$$

Where c_1 and c_2 are termed the cognitive and social learning rates. The set of two parameters control the relative importance of the memory of the particle itself to the memory of the neighborhood. The variable r and $\text{Rand}()$ are two random functions that is uniformly distributed in the range $[0,1]$. $X_i = (X_{i1}, X_{i2}, \dots, X_{iD})$ represents the i th particle. $P_i = (P_{i1}, P_{i2}, \dots, P_{iD})$ represents the best previous position of the i th particle. The symbol g represents the index of the best particle among all the particles. $V_i = (V_{i1}, V_{i2}, \dots, V_{iD})$ represents the velocity of the i th particle. Variable w is the inertia weight. The general process of PSO is as follows.

- Do
- Calculate fitness of particle
- Update p best if the current fitness is better than p best
- Determine best for each particle: choose the particle with the best fitness value of all then neighbors as then best
- For each particle Calculate particle velocity according to (1)
- Update particle position according to (2)
- While maximum iterations or minimum criteria is not attained

Since the presentation of the PSO calculation, a few upgrades have been recommended. In 1998, idleness weight was first proposed by Shi and Eberhart [12]. The capacity of dormancy weight is to adjust world wide

investigation and near by abuse. In the next year, Clerc proposed the choking variable s to guarantee the combination of PSO. Eberhart and Shicontrasted dormancy weight and narrowing components and tracked down that the tightening factors were preferable assembly over latency weight [2].

2.3 Dynamic and Adjustable PSO

In this segment, we propose two improved calculations called Dynamic and Adjustable Particle Swarm Optimization1 (DAPSO1) and DAPSO2. In DAPSOs, to change the speed of every molecule, all particles are determined the separation from its elf to the world wide best situation by the accompanying capacity.

$$\Delta x_{di} = |(x_{di} - x_{gbest})| \quad 2.3$$

$$FD_d = \text{Max}(\Delta x_{di}) \quad 2.4$$

Where x_{di} is the position of the i^{th} particle, x_{gbest} is the position of g best. FD_d is the furthest distance from the particle to g best. In DAPSO1, the velocity and position of each particle is adjusted by the following formulas:

$$V_{id} = WXV_{id} + c_1 X \text{rand}() (P_{id} - X_{id}) + C_2 X \text{Rand}() (P_{ad} - X_{id}) \quad 2.5$$

$$ac = \text{rand}() * 0.5$$

$$V_{new} = \begin{cases} V_{id} * \left(1 + ac_d * \frac{\text{Gene} - \text{Iter}}{\text{Gene}}\right) \frac{\Delta x_{di}}{FD_d} > 0.5 + ac_d \\ V_{id} * \left(1 - ac_d * \frac{\text{Gene} - \text{Iter}}{\text{Gene}}\right) \frac{\Delta x_{di}}{FD_d} < 0.5 - ac_d \\ V_{id} * 0.5 - ac_d \leq \frac{\Delta x_{di}}{FD_d} \leq 0.5 + ac_d \end{cases} \quad 2.6$$

$$X_{id} = X_{id} + V_{new} \quad 2.7$$

Where X_{id} is updated by the velocity which is adjusted by the distance from particle to the global best and is the adjustment coefficient




Figure 2.8 Three radius of $(0.5 - ac)$ to $(0.5 + ac) * FD_d$, and FD_d .




Figure 2.9 Adjust the velocity according the distance from the particle to g best.




Figure 2.10: Flowchart of DAPSO.

In Figure 2.10, x_1 , x_2 and x_3 all have difference distance from its elf to world wide high-quality function. X drops within the radius of $(0.5-ac)*FD_d$. The distance from x_2 to world wide first-rate role is between $(0.5-ac)*FD_d$ and $(0.5+ac)*FD_d$. X_3 drops beyond the radius of $(0.5+ac)*FD_d$ in DAPSO1. In DAPSOs, we outline the “long distance” as the space from the particle to the global first-class past $(0.5+ac)*FD_d$ and the “quick distance” as the gap from the particle to the world wide best is smaller than $(0.5-ac)*FD_d$. In DAPSO1, the debris far far from the world wide satisfactory have to be given larger cost of speed so it is able to discover an unknown vicinity, while those close to the global great have to be given

smaller cost of velocity so that it can make the most the neighborhood of the world wide satisfactory. In DAPSO2, if there had been many particles some distance far away from the world wide great function, then the velocities ought to be given a larger value. If there had been many debris near from the global excellent position, then the velocities need to take delivery of a smaller value. DAPSO best adjusts the velocity of the sure particle, how ever in DAPSO2, the velocities of all particles are adjusted together. The widespread waft of DAPSOs and the flow chart of DAPSO are shown as follows.

Step1. Initialization of a populace of particles with random positions and velocities

Step2. Evaluation of particles.

Step3. Calculate the distance from every particle to the global excellent position and shop the farthest distance within the memory.

Step4. Adjust particle's speed in line with its distance from its elf to the world wide exceptional role.

Step5. Update particle's function via the adjusted velocity.

Step6. Repeat Step.2~Step.5 until termination standards are met.

RESULTS AND DISCUSSION

This chapter covers the results in tabular form and plots along with the discussions over the result analysis. The work consists of the thesis objective of inclusion any DGina57 bus system at an optimum value for which the losses and cost can be minimized.

We can see that are complete 57 transport character numbers in section 1. The leftover sections addresses the separate transport voltage size, voltage point, power stream to stack and the force produced at the transports and the infused MVAR if any receptive gadget is set.

In the last columns the absolute misfortunes during the 57bus framework are shown. Here it tends to be seen that in standard 57 transport framework the complete misfortunes are 27.394MW as seen by NRLF techniques influence stream arrangements result. The complete age cost that is gotten here is 950685.6 \$/hr at the given upsides of generator and burden power esteems at various transports.

In the wake of producing the force stream arrangement of 57 transport, the line information, transport information and cost coefficient lattice are trading to the PSO calculation to refresh these 57bus information at various arbitrary mixes of $\{r \ a \ V \ P\}$. Here the information r is the irregular worth of line number in the middle of to 57. At this line the DG will be relied upon to put. The boundary 'a' is the extent of length of the of regarded line number 'r' at which DG is required to be put. Assume if $a=0.3$ and $r=13$ it implies the line number 13 is chosen for interfacing at the distance proportion 0.3 (for example 30%) of distance from the 'FROM' transport out of complete length. Essentially 'V' is boundary that addresses the worth of DG supply voltage in p.u. also, 'P' is the force of DG.

Figure shows the IEEE-57 bus system:




Figure 4. IEEE benchmarked 57-bus system

The Optimized parameter value for which minimum cost is obtained are given value along with their units.

Optimized parameter value

Line no. 66.00 Distance from line: 0.25
 Voltage: 1.28 pu Power: 15.00 MW

Hence it shows that if we take the 66 number line and place a DG of 15MW at the distance of 25% from the FROM bus of 66th line at voltage value of 1.28 pu then minimum cost will be 941390\$/hr at its optimum result value.

Figure 4.2 is obtained on plotting the value of minimum cost at each iteration. These values are minimum generation cost for the local best solution during the search of the PSO algorithm. Figure 4.3 is the average cost of all the DG's parameters which are updated by the PSO at every iterations. It shows that the PSO search approach is converging towards minimum cost. Initially the average cost for all possible DG's at their initial random parametric values of [r a V P] is near about 1.26×10^6 \$/hr but as iteration increases the cost is monotonically decreases with respect to each iterations. Hence this plot represents that the PSO is working successfully and capable of finding better minimum cost in every new iteration as compared to previous iterations.




Figure 4.2: Minimum cost vs. iterations




Figure 4.3: Convergence Plot




Figure 4.5 c: DG voltage of optimized particles

Figure 4.5 d: DG rated power of optimized particles

Figure 4.5 a to shows the parametric worth of all the advanced molecule at particular id got on arriving at the last round of streamlining search as far as DG area according to line id, its separation from to transport for line id, it voltage rating in pu and its evaluated power in MW.

Likewise at various emphasis and number of particles a few times the PSO streamlining calculation is run for a few times and best advanced arrangements with better expense and lower misfortunes are thought of. The similar qualities wrt 57bus and upgraded 58 transport with DG arrangement are displayed in figure 4.6.




Figure 4.6: Selected optimized result with better performance cost wrt 57 (blue) and optimized 58 bus systems.

CONCLUSION AND FUTURE SCOPE

The simulated DG are assumed to be set up at extraordinary buses and the entire device power loss turned into received in each case. It is observed from this discern that overall feeder strength loss reaches a minimal price while the DG is optimally located. The theoretical most effective role to vicinity the DG is found and the technology with admire to call for. The position along with this distance from the quit of feeder and different parameters are discover using PSO.

- The PSO based totally most fantastic DG parameters estimator is designed the makes use of of MATLAB programming algorithm.
- It has been proved that this optimization set of rules is pretty effectives for hastily locating the changes required in insertion of greater DG’s location, voltages and electricity rankings in each the simulated and real-internationalel ectricity device scenarios taken into consideration.
- The information optimization technique has proven a ability to no longer simples thastily discover huge modifications to electricity machines modes, but has more over been able to perceives the mode which has changed.
- Multisite measurements may be drastically applied to provide greater self-belief insides the detectional arming.
- This has vast implications for electricity application intervention strategies.

- Importantly, the approach is computationally green and can without problems be completed in real-time.
- This work presents optimization techniques to determine the most beneficial area for placing DG in each radial and networked structure to limit energy losses.
- In future an approach can be proposed which can be primarily based on non-iterative algorithms, like energy waft packages. Therefore, there may be no convergence issues concerned, and consequences could be received in no time.
- A collection of simulation studies can be carried out to verify the validity of the proposed strategies, and effects may be discovered on proposed strategies in future.
- In exercise there are other constraints which may affect the DG placement. Nevertheless, methodologies presented in this painting can be powerful, instructive, and beneficial that can also be taken into consideration for the machine designers in choosing right websites to area DGs.
- In destiny this paintings may be very useful as a way to decide the optimal place and size of DGs.
- It may be implemented as a web provider which is used by energy businesses. In this simply wished to tug the bus facts as an instance IEEE-57 bus records and the DGs configuration and they'll get the result for allocation of DGs on which bus with which configuration.
- Also in destiny one device gaining knowledge of version may be developed that can predict the DGs length and vicinity by itself each time needed to apply any DG in generation gadget.

REFERENCES

- [1] S. H. Lee and J. W. Park, "Selection of optimal location and size of multiple distributed generations by using Kalman filter algorithm," *IEEE Trans. Power Syst.*, vol. 24, no. 3, pp. 1393–1400, Aug. 2009.
- [2] H. Farhangi, "The path of the smart grid," *IEEE Power Energy Mag.*, vol. 8, no. 1, pp. 18–28, Jan./Feb. 2010.
- [3] Technical Report, "Monthly All India Installed Generation Capacity Report, June 2014", Central Electricity Authority (CEA) of India.
- [4] Prof. Asok Raj Kumar and Er. Ramjeyanth K.R.S "Outburst of Renewable Energy in India. Is it towards the target" International Conference on Advances in Engineering, Science & Management (ICAFSM-2012), March 2012.
- [5] www.ren21.net/wp-content/uploads/2016/06/GSR_2016_Full_Report.pdf
- [6] P. Alemi and G. B. Gharehpetian, "DG allocation using an analytical method to minimize losses and to improve voltage security," in *Proc.*
- [7] A. A. Chowdhury, S. K. Agarwal, and D. O. Koval, "Reliability modeling of distributed generation in conventional distribution systems planning and analysis," *IEEE Trans. Ind. Appl.*, vol. 39, no. 5, pp. 1493–1498, Sep./Oct. 2003.
- [8] A. Ipakchi and F. Albuyeh, "Grid of the future," *IEEE Power Energy Mag.*, vol. 7, no. 2, pp. 52–62, Mar./Apr. 2009.
- [9] Statistics Korea. (2010). Car Registration Status, Daejeon, South Korea.[Online]. Available: http://www.index.go.kr/egams/stts/jsp/potal/stts/PO_STTS_idxMain.jsp?idx_cd=1257&bbs=INDX_001&class_div=A
- [10] Korea Power Exchange. (2010). Demand and Supply Result, Seoul, South Korea.[Online]. Available: <http://www.kpx.or.kr/KOREAN/htdocs/main/sub/bidYesterdayList.jsp?cmd=&curpage=103>
- [11] Y. G. Hegazy, M. M. A. Salama, and A. Y. Chikhani, "Adequacy assessment of distributed generation systems using Monte Carlo simulation," *IEEE Trans. Power Syst.*, vol. 18, no. 1, pp. 48–52, Feb. 2003.
- [12] D. Singh, R. K. Misra, and D. Singh, "Effect of load models in distributed generation planning," *IEEE Trans. Power Syst.*, vol. 22, no. 4, pp. 2204–2212, Nov. 2007.
- [13] W. El-Khattam, Y. G. Hegazy, and M. M. A. Salama, "An integrated distributed generation optimization model for distribution system planning," *IEEE Trans. Power Syst.*, vol. 20, no. 2, pp. 1158–1165, May 2005.
- [14] C. Wang and M. H. Hehrir, "Analytical approaches for optimal placement of distributed generation sources in power systems," *IEEE Trans. Power Syst.*, vol. 19, no. 4, pp. 2068–2076, Nov. 2004.
- [15] R. Karki and R. Billinton, "Reliability/cost implications of PV and wind energy utilization in small isolated power systems," *IEEE Trans. Energy Convers.*, vol. 16, no. 4, pp. 368–373, Dec. 2001.